

69903099

MAR 13 1982

TA 710:3
H3
H64
No 78



S.P. 78
FOR REFERENCE
not to be taken from this room

SAN GABRIEL
ANAHEIM
VENTURA
HONOLULU
KAHULUI, MAUI

2153 NORTH KING STREET, HONOLULU, HAWAII 96819

(808) 839-9071

July 26, 1982
Project No. H-0358-C

Mrs. Phyllis Hayashida
47-632 Mapele Road
Kaneohe, Hawaii 96744

Subject: Site Filling
Hayashida Residence

Dear Mrs. Hayashida:

This is to inform you that the house pad fill has been satisfactorily completed. The filling operation consisted of the following:

1. Clearing of surface vegetation and debris.
2. Stabilizing the soft soils with a layer of large material. This material was placed over the soft soils and track rolled with a dozer to produce an unyielding surface.
3. Permanent fill was then placed over the stabilized surface and compacted.
4. On the permanent fill, a five (5) foot surcharge was placed and survey readings taken to determine rates of settlement.

Survey readings were taken from June 3 through June 29, 1982 to determine the settlement rates of the surcharge. The readings indicated the settlement had slowed to less than 1/16th inch per day during the last set of readings. After the last set of readings, we recommended removal of the surcharge. The surcharge material was to be placed in the yard/farm area.

Based on the observations, it is concluded that the contractor has satisfactorily completed the earthwork, as specified in our soils report and grading plan.

MUNICIPAL REFERENCE & RECORDS CENTER
County of Honolulu
Hall Annex, 558 S. King Street
Honolulu, Hawaii 96813

WITHDRAWN

Mrs. Phyllis Hayashida
July 26, 1982

Should you have any questions or require any further information, please do not hesitate to contact us.

Very truly yours,

SOILS INTERNATIONAL

Lawrence S. Shinsato

Lawrence S. Shinsato, P. E.
Vice-President



LSS:lcs

cc: Mr. Richard Kong
Joe Silva

log ✓
list ✓
card ✓

SR - 78

201-21-0382

Date: August 13, 1982

TO: Mr. Philip M. Carlos
47-632 Maple Road
Kaneohe, Hawaii 96744

Dear Mr. Carlos:

Re: ~~YOUR PROJECT AT 47-632 MAPLE ROAD~~
~~TRK: 4-7-29: 21~~

We are sending you herewith

Under separate cover


No. of Copies	Description
1	Approved Grading Permit No. 303

For:

Your information and use Approval
 Review and comment Signature
 As requested

Remarks:

The date of our approval, August 12, 1982, is the closing date of the permit. The bond filed with the City for the grading work shall remain in effect for a period of one year after the closing date; therefore, it will be returned to you on August 12, 1983.


 MICHAEL J. CHUN
 Director and Chief Engineer

JL:mb
 Attach.
 cc: Lawrence S. Shinsato
 Hawaiian Insurance & Guaranty Co.
 bcc: Service Engineer w/original

PERMIT CLOSED

PERMIT NO. 303

DEPARTMENT OF PUBLIC WORKS
CITY AND COUNTY OF HONOLULU

182X0828

To the Director and Chief Engineer
Department of Public Works
City and County of Honolulu

APPLICATION AND PERMIT FOR

GRADING

DEPT 24 ENG 12
06/28/82 T20011
R078 044996 041

Application is hereby made to do grading work in conformity with Chapter 23, R. O. 1978, As Amended, as follows:

TAX MAP KEY					ENG. SOILS REPORT	EST. QUANTITY	PERMIT FEE	FEE RECEIVED
ZONE	SEC.	PLAT	PAR.	LOT	DATE FILED:	EXCAV. CU. YD.	\$	\$
4	7	29	21			0		\$ 82.50
						FILL CU. YD. 1743	\$ 82.50	BY: <u>[Signature]</u> DATE: 6/23/82

Located at 47-632 MAPELE ROAD

Lot Area _____ Sq. Ft. 0.891 Acres

Description of Soil
Fill Material soil & rock
Existing Ground _____

Estimated Starting Date June 29, 1982 Estimated Completion Date June 29, 1983

Remarks/Purpose of Work: to grade site for proposed dwelling. Continued from G.P. No. 9844.

Owner M/M Philip M. Carlos Address 47-632 Mapele Road. Phone 239-8583

Engineer Lawrence S. Shmisato Address #4169-E Phone _____

Contractor JOE SILVA BULLDOZING, S.V.S. Address P.O. Box 1086, Kaneohe 96744 Phone 239-8483

Date of Application June 28, 1982 Permittee [Signature]

Application Reviewed By _____ Date _____ 19____
SERVICE ENGINEER

To the Applicant:
Permission is hereby given to do the above work according to the conditions hereon and according to the approved plans and specifications pertaining thereto, subject to compliance with Chapter 23, R. O. 1978, As Amended.

Remarks: _____
Date June 28, 1982

Issued By: [Signature]
FOR DIRECTOR AND CHIEF ENGINEER, DEPT. OF PUBLIC WORKS

Contractor shall notify this office two working days before commencing any work and arrange for necessary inspectional services.

THIS PERMIT WILL EXPIRE UNLESS WORK IS STARTED WITHIN 90 DAYS FROM DATE OF ISSUE; OR IF WORK IS SUSPENDED OR ABANDONED FOR 60 DAYS OR MORE AFTER WORK IS BEGUN; OR ONE YEAR FROM DATE OF ISSUE

I hereby certify that all work as requested above has been completed in conformity with Chapter 23, R. O. 1978, As Amended and in accordance with the approved plans and specifications.

Date 8/10/82 1982 Permittee [Signature]

Date August 12, 1982 Approved By: John C. Lee

Final Soils Report _____ Date Filed _____ 19____

7/19/82 Rough grading almost completed
observed workmen setting up batter for house
2 hoptos on project
8/9/82 Talked with Mr KONG of KONG TRUCKING & he
shows me a letter from soils & environmental station
that work completed.

WITHDRAWN
MUNICIPAL REFERENCE RECORDS CENTER
City & County of Honolulu
City Hall Annex, 558 S. King Street
Honolulu, Hawaii 96813